

**CON EDISON
REQUIREMENTS
FOR
ELECTRIC SERVICE
INSTALLATIONS**

November 2009

CONTENTS

PAGE NO.

<u>IMPORTANT NOTICE REGARDING CON EDISON SPECIFICATIONS</u>	<u>A</u>
<u>SECTION I – INTRODUCTION.....</u>	<u>4</u>
<u>SECTION II – DEFINITIONS.....</u>	<u>7</u>
<u>SECTION III – GENERAL INFORMATION AND REQUIREMENTS</u>	
Application for Service.....	9
Temporary Service	9
Access to Customer's Premises	9
Identification of Employees.....	9
Electrical Customer Work Request.....	10
Characteristic of Electric Service	11
High Tension Service	11
Load Balance	12
Service Taps	12
Unauthorized Attachment to Poles	12
Submetering.....	13-13A
Overhead Distribution Clearances	13B
<u>SECTION IV – SERVICE CONNECTIONS</u>	
General	14
Extensions of Electric Distribution Lines for New Residential Subdivisions	14
Overhead Service Connections from Overhead Distribution Lines.....	15
Underground Service Connections	15

	<u>PAGE NO.</u>
Space for Transformer Apparatus.....	17
Interior Distribution Installation	17
Excess Distribution Facilities	17
Change in Location of Existing Service Facilities.....	18
Loop Services.....	19
<u>SECTION V – SERVICE EQUIPMENT</u>	
General	20
<u>SECTION VI – GROUNDING.....</u>	<u>22</u>
<u>SECTION VII – METERING INSTALLATIONS</u>	
General	23
Company Furnishes and Installs.....	23
Company Furnishes – Customer Installs	23
Customer Furnishes and Installs	24
Meter Mountings-Self Contained 120/208 or 120/240 Volt Services	24
Meter Mountings-Socket Installations for Street Celebrations, Bazaars, and Other Events Requiring a Temporary Service.....	25
Table I Maximum Line and Load Conductor Sizes For Socket Equipment Types	26
Current Transformer Meters	26
Table II and Table III...Current Transformer Mounting Spec #'s.....	27
Outdoor Metering	28

	<u>PAGE NO.</u>
Indoor Metering	29
External Demand Metering	29
Temporary Construction Service	29
Location.....	29
Identification of Circuits	32
Seals	32
Spacing Requirements	32A
 <u>SECTION VIII – MOTORS AND CONTROLLERS</u>	
General	33
Motor Protection	33
Motor Installation	33
Inrush Current Limits	34
 <u>SECTION IX – MISCELLANEOUS APPARATUS/VOLTAGE SENSITIVE EQUIPMENT/VOLTAGE DROP.....</u>	
	<u>36</u>
Voltage Drop	36A
Steady State Voltage.....	36B, 36C
 <u>SECTION X – CAPACITORS</u>	
	<u>37</u>
 <u>SECTION XI – CUSTOMER’S STAND-BY GENERATORS</u>	
	<u>38</u>
 <u>SECTION XII – CARRIER CURRENT SYSTEMS</u>	
	<u>40</u>
 <u>SECTION XIII – AESTHETICS.....</u>	
	<u>40A-J</u>

SECTION XIII – STANDARD SERVICE LAYOUTS

General	41
Guidelines for Installation of Electric Service Laterals to Residential Dwellings.....	43
New Detached Homes – Underground	44
New Detached Homes – Overhead	44A
New Semi-Attached Homes – Underground	45
New Semi-Attached Homes – Overhead	45B, 45C
New Attached/Row Houses – Underground	46
New Attached/Row Houses – Overhead.....	46B, 46C
New Small Commercial Building – Underground	47
New Small Commercial Building – Overhead	47A
New Multi-Tenanted Residential Building with Direct Metering – Overhead	48A
Rewiring of Existing Premises	49

SECTION XIV – APPROVED ELECTRIC SERVICE EQUIPMENT

Index	Approved Electric Service Equipment	50, 50A
Table I	Service End Boxes for Underground Service.....	51
Table II-V	<u>Meter Mounting Equipment:</u>	
	AC Socket Type Watt-hour Meters	51A-56A

	<u>PAGE NO.</u>
Table VI Meter Mounting for External Demand Meters	57
Table VII Metering Mountings for AC Bottom Connected Watt-hour Meters	57
Table VII-A CT Socket Meter Enclosure for 3 Phase 4-Wire Wye Services and 3W Delta Low Tension Services	57A
Table VIII Current Transformer Cabinets (Eng Spec 142)	58
Table IX Trans-S Mounting for CT's and Socket Meter for 3 Phase 4 Wire Wye Service.....	58
Table X Trans-A Mounting for CT's for Non Standard CT Services and 3 Wire Residential Use.....	58A
Table XI Trans-A Mounting for CT's and Meter for 3 Wire Residential Use	58A

SECTION XV – ELECTRIC SPECIFICATIONS

A. SERVICE END BOXES – Underground

<u>E.O. 6217</u> - Sealing Service Cable and Conduit	59, 59A
<u>E.O. 6208-C</u> - Basement, At Property Line – Indoor Metering	60
<u>E.O. 6209-C</u> - Basement, Back of Property Line, No Property Line Box – Indoor Metering.....	61
<u>E.O. 6210-C</u> - Property Line Splice Box Requirements	62
<u>E.O. 6211-C</u> - Building Without Basement at Property Line – Indoor Metering.....	63
<u>E.O. 6212-C</u> - Building without Basement, Back of Property Line, Without Property Line Box – Indoor Metering	64
<u>E.O. 6214-C</u> - Sub Sidewalk Space, outside of Property Line – Indoor Metering.....	65

E.O. 6215-B - Building With or Without Basement, Back of Property Line, Without Property Line Box – Outdoor Metering 66

MES 205 - Service End Box Indoor or Outdoor Service End Box – 10” x 10” x 5” 68

MES 215 - Service End Box for Indoor or Outdoor Locations 24” x 12” x 8” 69

MES 400 - Service End Box for Indoor Co Occupied Service Pipe – 12” x 12” x 8” 70*

MES 484 - Service End Box for Indoor or Outdoor Locations 30” x 18” x 12” 71

E.O. 9525-B - Customer’s 120/208-Volt Electric Service Space Requirements for Company Cables in Service End Boxes, 1-500 KCMIL Copper Cable Per Phase 72

E.O. 9072-B - Customer’s 120/208-Volt Electric Service Space Requirements for Company Cables in Service End Boxes Maximum 2-500 KCMIL Copper Cables Per Phase Company Cables..... 73

E.O. 9073-B - Customer’s 120/208-Volt Electric Service Space Requirements for Company Cables in Service End Boxes, Maximum 3-500 KCMIL Copper Cables Per Phase Cables 74

348209 - Customer’s 265/460-Volt Electric Service Space Requirements for Company Cables in Service End Boxes, 1-500KCMIL Copper Per Phase Cable 74A

348210 - Customer’s 265/460-Volt Electric Service Space Requirements for Company Cables in Service End Boxes, Max. 2-500 KCMIL Cooper Per Phase Cables..... 74B

Note: Asterisk indicates spec prints 11” X 17”.

348211 - Customer's 265/460-Volt Electric Service Space Requirements for Company Cables in Service End Boxes, Max. 3-500 KCMIL Copper Per Phase Cables..... 74C

B. UNDERGROUND RESIDENTIAL DISTRIBUTION

E.O. 14221-C Splicing and Installation Direct Buried Service Cables..... 75

E.O. 16833-B Service Lateral and External Loop Service 75A

E.O. 16696-D Clearance for Planting Around Transformer Pads 76

C. SERVICE CONNECTIONS – OVERHEAD

E.O. 6218-B Customer's Overhead Service Conductors 77-77A4

E.O. 100186 Non-Tension Overhead Connectors for Aluminum or Copper Secondary Conductors 77B1

E.O. 8746-B Customer's Electric Services Overhead to Pipe Masts And Clearance 78A-78B

E.O. 16883-B Customer's Property Pole for Low Tension Service..... 78C

324862 Drawing: Temporary Service for maximum span of 75 feet on same side of street..... 78D

E.O. 4647-C Overhead Distribution Clearances 78E1-78E6

D. METERING

<u>MES 528</u>	Space Requirements for Metering Closet	79
<u>MES 394</u>	Outdoor Watt-hour Meter Sockets.....	80
<u>MES 395</u>	Watt-hour Meter Sockets on Line Side of Service Disconnects	81
<u>MES 447</u>	Watt-hour Meter Sockets on Load Side of Meter Disconnects..... (Page 1 of 2)	82
<u>MES 447</u>	Watt-hour Meter Sockets on Load Side of Meter Disconnects..... (Page 2 of 2)	83
<u>MES 194</u>	Self-Contained Three-Phase, Four Wire Watt-hour Meter.....	84
<u>MES 745</u>	Trans “A” Cabinet for Low Voltage 200 Amp or 400 Amp Service.....	85*
<u>MES 750</u>	Trans “A” Cabinet for Low Voltage 400 Amp or 800 Amp Service.....	85A*
<u>MES 755</u>	Trans “S” Cabinet for Low Voltage 200 Amp or 400 Amp 3 Phase, 4 Wire Wye Service.....	85B*
<u>MES 757</u>	Trans “S” Cabinet for Low Voltage 400 Amp or 800 Amp 3 Phase, 4 Wire Wye Service.....	85C*
<u>MES 195</u>	Wiring diagram – 200 to 800 Amp, Bar-Type Current Transformer.....	86
<u>MES 751</u>	Form 9S Meter Socket enclosure.....	86A
<u>MES 142</u>	Current Transformer Cabinet – Not More Than Two Sets 500 MCM Cu, or 750 MCM AL Cables Per Phase	87*

Note: Asterisk indicates spec prints 11" X 17".

<u>MES 298</u>	Current Transformer Cabinet – Three or Four Sets of 500 MCM Cu or 750 MCM Al Cables Per Phase or Smaller	88
<u>MES 377</u>	Current Transformer Cabinet – Capacity Greater Than 4-500 MCM Cu or 4-750 MCM AL Cables Per Phase	89*
<u>E.O. 16700-B</u>	Demand Meter Equipment – MES 104-2 Devices.....	90
<u>E.O. 15934-B</u>	Demand Meter Equipment MES 104-A W/Fuse Block.....	91
<u>E.O. 16701-B</u>	Demand Meter Equipment – MES 105 – 3 Devices	92
<u>SPEC 108</u>	Demand Meter Equipment – 1 Device.....	93
<u>E.O. 16589-B</u>	Demand Meter Equipment – MES 108-A – W/Fuse Block.....	94
<u>SPEC 151</u>	Demand Meter Equipment–Mounting Device for Indicating/Cumulative Demand.....	95
<u>MES 732</u>	Wiring Diagram for 200 amps Trans-A Cabinet for (Residential use in Westchester Only)	95A

E. PROPERTY LINE BOX CONFIGURATIONS

<u>E.O. 16736-B</u>	- Customer Property Line Box 2' x 2'8" x 2'	96
<u>E.O. 9700-C</u>	- Distribution Box – 3'6" x 2'9" x 2'	100
<u>E.O. 10265-B</u>	- Property Line Box – 3'6" x 2'9" x 2'	101
<u>E.O. 10266-B</u>	- Property Line Box – 3'6" x 2'7" x 2' slotted.....	102

Note: Asterisk indicates spec prints 11" X 17"

E.O. 10262-C - Property Line box – 4’6” x 3’6” x 4’103

E.O. 10263-B - Property Line box – 4’6” x 3’6” x 3’11”..... 104

E.O. 10264-B - Property Line box – 4’6” x 3’6” x 4’ slotted.....105

E.O. 9316-C - Distribution Box Type
S3C – (Special Applications).....106

E.O. 13331-B - Distribution Box Type DB6 – 6’ x 4’x 5’ HR107

E.O. 2164-B - Cable Manhole Type M11-6-11’6” x 4’6” x 6’6”108

E.O. 11924-B - Property Line Cable Manhole – 11’6” x 4’6” x 6’.....109

F. PROPERTY LINE BOX – Cable Arrangements

E.O. 11626-B - Company: 3 Sets of 4-500 MCM CU
Customer: 3 Sets of 4-500 MCM CU..... 110

E.O. 12809-B - Company: 2 Sets of 8-4/0 MCM CU
Customer: 3 Sets of 4-350 MCM AL 111

E.O. 11693-B - Company: 4 Sets of 4-500 MCM CU
Customer: 6 Sets of 4-500 MCM CU..... 112

E.O. 12791-B - Company: 4 Sets of 8-4/0 MCM CU
Customer: 6 Sets of 4-350 MCM AL 113

E.O. 12466-B - Company: 8 Sets of 4-500 MCM CU
Customer: 10 Sets of 4-500 MCM CU..... 114

E.O. 14608-B - Company: 8 Sets of 4-500 MCM CU
Customer: 10 Sets of 4-750 MCM AL 115

E.O. 11041-B - Company: 12 Sets of 4-500 MCM CU
Customer: 15 Sets of 4-500 MCM CU..... 116

E.O. 11934-B - Company: 16 Sets of 4-500 MCM CU
Customer: 20 Sets of 4-500 MCM CU..... 117

E.O. 12810-B - Company: 12 Sets of 4-500 MCM CU
Customer: 15 Sets of 4-750 MCM AL 118

E.O. 12811-B - Company: 16 Sets of 4-500 MCM CU
Customer: 20 Sets of 4-750 MCM AL 119

E.O. 12893-B - 265/460 - Company: 6 Sets or 4-500 MCM CU
Customer: 12 Sets of 4-500 MCM CU..... 120

E.O. 12908-B - 265/460 - Company: 8 Sets or 4-500 MCM
CU Customer: 16 Sets of 4-500 MCM CU..... 121

SECTION XVI – INSULATION REQUIREMENTS

New York State Residential Insulation Standards

New Construction & Additions to Existing Homes..... 122

Typical Materials to Satisfy Insulation-Alone “R” Values 123

Long Island Power Authority Notice (LIPA) Notice 124

SECTION XVII – FREQUENTLY REQUESTED SPECIFICATIONS AND DRAWINGS

Frequently Requested Specifications and Drawings 125

(Note: Scroll the listings until you find the Spec or Drawing needed, and “click” to view and or print.)

IMPORTANT NOTICE

REGARDING

CON EDISON SPECIFICATIONS

Any change or modification to our specifications or Service Layouts requires ADVANCE approval from the company.

Our specifications have been designed with great care to assure compliance with all the various codes and safety requirements. Changing anything without prior approval will result in the job not being accepted.

Delays will result because the contractor will be required to correct the change, at the contractor's expense.

There is also the possibility that a code or safety violation will be created.

Service Layouts (2-80) are a commitment by us of our requirements and our service characteristics. Remember, any change from the type of equipment, the location, or point of entrance (POE) requires advance approval.

We are always ready to discuss anything while it's in the planning stage. However, when it's after the fact, it usually results in your re-doing the job, this time according to the company specifications and the Service Layout.

November 2009