01-07-00	1
DRAWN BY: BURKE, J.	
REVISIONS	
03-06-03	1
WONG, J	
11-14-05	2
Abdalla, A	
Revised for digital meter installation	
8-14-06	3
Abdalla, A	
Revised to add # 10 AWG ground wire for use with digital Vortex meter in future	



NOTES FOR ELECTRICAL INSTALLATION

A) INSTALLATION SHALL MEET THE REQUIREMENTSOF THE "ELECTRIC CODE OF THE CITY OF NEW YORK" AND BE SUBJECT TO THE APPROVAL OF REGULATORY AUTHORITIES HAVING JURISDICTION.

B) ALL CONDUCTORS SHALL BE COLOR CODED AND NUMBERED AS INDICATED AND BE OF SUFFICIENT AWG SIZE. ALL CONNECTIONS SHALL BE MADE ON TERMINALS AS SHOWN AND NOT SPLICED. STRANDED WIRE SHALL BE CONNECTED TO TERMINAL BY CRIMPS

C) ALL MATERIAL AND WIRING SHALL BE FURNISHED AND INSTALLED BY THE CONTRACTOR EXCEPT AS NOTED. BALL VALVE AND TOTALIZER SUPPLIED BY THE COMPANY.

D) THE METER PAN SHALL BE INSTALLED AT A MINIMUM HEIGHT OF 3'-6" AND A MAXIMUM HEIGHT OF 4'-9" FROM FLOOR TO BOTTOM OF PAN. A HEIGHT OF 4'-0" IS PREFERRED WHERE PRACITCAL. NOTE: THE METER PAN IS LONG LEAD DELIVERY ITEM.

E) UNMETERED CONDUCTORS SHALL BE IN RIGID STEEL CONDUIT OR TROUGH EXCEPT FOR THE CONNECTION TO THE MOTOR OR INSTRUMENT TERMINAL BLOCK. TO FACILITATE CHANGE OF EQUIPMENT, A MINIMUM OF 18"-30" OF FLEXIBLE, METALLIC, LIQUID TIGHT CONDUIT SHALL BE USED. A TERMINAL BOX SHALL BE USED TO CONNECT THE FLEXIBLE CONDUIT TO THE RIGID CONDUIT. THE TERMINAL BOX SHALL BE LOCATED AT A HORIZONTAL DISTANCE OF APPROXIMATELY 9" FROM THE METER BODY.

F) ALL POWER SUPPLY CABLE SHALL BE SOLID WIRE, THW TYPE, AWG SIZE AS REQUIRED BY 'ELECTRIC CODE OF THE CITY OF NEW YORK.'

G) VORTEX METER & PRESSURE TRANSMITTER: GROUND SHIELDS AT KEP ONLY.

H) SIGNAL WIRE AND/OR CONDUCTORS WITHIN INSTRUMENT PANEL SHALL BE #16 AWG, STRANDED, (4 CONDUCTOR 2 TWISTED SHIELDED PAIRS), OVERALL SILVER PLATED COPPER SHIELDING (600 V, 200°C RATING) TYPE UNLESS NOTED OTHERWISE IN DRAWINGS COLOR COATED AS INDICATED

I) A.C. SUPPLY TO BE FROM LINE SIDE OF COMPANY METER. COMPANY TO MAKE FINAL CONNECTION TO SERVICE.

J) LEAVE ENOUGH SLACK WIRE AT ALL TERMINAL POINTS. 12" IN MOTOR TERMINAL BOX AND PANEL TROUGH.

K) ALL EQUIPMENT, ENCLOSURE AND CONDUIT FITTINGS PROVIDING ACCESS TO UNMETERED ELECTRIC WIRING SHALL BE SEALABLE.

L) AN A.C. POWER OUTLET (3-PRONG, DUPLEX OUTLET WITH GFI) SHALL BE INSTALLED AT THE BOTTOM OF THE METER PAN TO PROVIDE ELECTRICITY FOR OPERATION OF PORTABLE EQUIPMENT.

M) THE NEGATIVE LEAD OF THE VORTEX METER SIGNAL CIRCUIT SHALL BE GROUNDED AT THE EARTH GROUND.

Grounding Preference:
1. Water Main Shut-Off, Street side
2. Building Steel, scraped clean
3. Test for <1 Ohm Resistance to Ground

COMPUTER GENERATED DRAWING NOT TO BE HAND REVISED

WIRING DIAGRAM FOR INSTALLATION OF TWO SEGREGATED VORTEX METERS (ANALOG VERSION) AND TWO KEP FLOW COMPUTERS

CONSOLIDATED EDISON COMPANY OF N.Y. INC.
STEAM ENGINEERING DEPARTMENT

DATE: 3/06/03	DWG. NO. S-619 REV. 3
LAST REV. 8-14-06	