











E0-5274-B	
REVISIONS	
CHANGED CABLE PULLING EYE	2
J.P.	
M. MEZA	3
10/14/09	
FOR RECORD AND INFORMATION ONLY	
G.D.	10/14/09
	4
REDRAWN INTO AUTOCAD. REPLACED REFERENCE TO LEAD SLEEVE WITH CABLE SPLICE. REPLACED 2'-2" DIMENSION WITH "VARIES". REMOVED MANUFACTURE NAME OF PORCELAIN GUIDE.	
REVISED BY D.J.T. APPROVED BY D. YOUNG	5
ADDED EXCEPTION NOTES WITH RESPECT TO CHAMBER SIZING AND COMPARTMENT ELIMINATION. CONSOLIDATED NOTES SECTION. MINOR DETAIL CLARIFICATION ADDED.	
REVISED BY A.A. APPROVED BY D. YOUNG	6
CHANGE DOOR SIZE FOR EXCEPTION 2.	
REVISED BY J.F. APPROVED BY D. YOUNG	
CONSTRUCTION STD. MANUAL NO. 3 SECTION 32 MANHOLES CABLES	



NOTES:  
 THE STEEL WIRES OF THE  
 NEUTRAL CABLE AND THE  
 LEAD SLEEVE (WHEN PRESENT) OF  
 THE JOINT SHALL BE BONDED TO  
 THE GROUND BUS.  
 CONDUIT NOTE  
 WHEN RADIUS OF BEND STARTS  
 INSIDE SPLICE CHAMBER, CABLE  
 RACKING TO BE ON SIDE WALL.  
 GROUNDING NOTE  
 GROUND BUS TO BE CONTINUOUS  
 THINED 2" x 1/4" COPPER BUS INSTALLED  
 ON BACK AND SIDE WALLS. CUT  
 BOILER PLATE AS REQUIRED.  
 CONNECT ENDS OF GROUND BUS  
 USING TIN PLATED SCREWS TO  
 TWO SYSTEM GROUND POINTS.  
 TERMINATE INCOMING CON EDISON  
 FEEDER #4/0 NEUTRAL CABLES  
 AND OUTGOING CUSTOMERS NEUTRAL  
 CABLES AT THE SPLICE CHAMBER  
 GROUND.  
 GROUND THE FLAT STRAP NEUTRAL  
 OF PRIMARY CABLE AND THE JOINT  
 WIRE AS SHOWN ON LATEST  
 REV OF DRAWING 322833 & 322834.  
 ALL BOILER PLATE BARRIERS  
 ANGLES, CABLE SUPPORTS, DOORS  
 AND FRAME AND CONDUITS TO BE  
 BONDED TO GROUND BUS.

**TYPICAL SPLICING AND SUPPORT CHAMBERS AT TOP AND BOTTOM OF PRIMARY RISERS**

CONSOLIDATED EDISON COMPANY OF N.Y., INC.  
 ELECTRICAL ENGINEERING DEPARTMENT  
 OUTSIDE PLANT BUREAU

PURPOSE:  
 TO BE USED IN CUSTOMERS PREMISES ON PRIMARY RISERS

DATE 4/29/49  
 LAST REV. 4/10/2014

DWG. NO. E0-5274-B REV 6

SUPERSEDES U.E.L.&P. CO. INC. DWG NO. 11120