







EO-8302-B

REVISIONS

L.D. VAZ 11/6/91	4
REDRAWN TO CADAM, ADDED SQUIRREL GUARD AND 3" CONDUIT, CHANGED FIBER TO PVC. J.P. J.L.L. 10/21/91	
L. ORTEGA	5
ADDED DIMENSIONS AND STOCK NUMBER FOR SQUIRREL GUARD	
W.S. 11/18/93 J.P.	
L. ORTEGA	6
REVISED TO ADD BEND DETAIL, DUCT EDGE PVC FAIR LEADER AND TWO PIECE PVC RISER	
7/23/02 J.T.A.	
L. SCALLY 12/8/03	7
ADDED FM#23 INFO, DELETED FM#7, 8, & 10 INFO, REVISED C/S/STK# FOR SQUIRREL GUARD, CHANGED 2 PIECE PVC TO U SHAPED.	
J.T. ABRUSCATO 12/8/03	
C. GRABOWSKI 05/12/08	9
ADDED U-BOLT DETAIL, NOTE AND STOCK NUMBERS FOR RISER PIPE, CHANGED SPEC. NUMBER FOR R & N WIRE SPEC.	
J.T. ABRUSCATO 4/7/04	
C. GRABOWSKI 4/7/04	8
ADDED U-BOLT DETAIL, NOTE AND STOCK NUMBERS FOR RISER PIPE, CHANGED SPEC. NUMBER FOR R & N WIRE SPEC.	
J.T. ABRUSCATO 4/7/04	
E. MCFARLANE 11/08/07	9
ADDED CLASS/STOCKS NUMBERS TO RISER PIPE, STRAPS, DUCT PROTECTOR AND CABLE HOLDER. ADDED REFER SPECS AND DWG NUMBERS. ADDED GROUNDING ROD, MOLDING AND STAPLES TORISER POLE DETAIL.	
H.J.M. 11/09/07	
FIELD MANUAL NO. 23 OVERHEAD CONST. SECT. 5.1: RISERS GENERAL	
FIELD MANUAL NO. 3 CABLE PULLING SECT. 2: OVERHEAD	
FIELD MANUAL NO. 9 O.H. SUPERVISORS SECT. 2: RISERS	
FIELD MANUAL NO. 16 SERV. INSPECTION & CONTROL SECT. 4: ELECT. SERV.	
FIELD MANUAL NO. 20 SERV. DETERMINATION HANDBOOK SECT. 3: UNDERGROUND	
CONSTRUCTION STDS. MANUAL NO. 3 SECTION 7 SERVICES AND RISERS	



RISER CABLE SQUIRREL GUARD
STOCK NUMBER 554-6007

MAT'L. GALV. WIRE MESH, 1/2" x 1/2" NO. 19 GAUGE

PRIMARY AND SECONDARY CABLE RISERS

CONSOLIDATED EDISON COMPANY OF N. Y. INC.
DISTRIBUTION ENGINEERING DEPT.

DATE 5/18/57
LAST REV. 11/09/07
DWG. NO. **EO-8302-B** REV. **9**

CHECK APPROVAL	DIV	SIGNATURE	DATE	DRAWN BY	DATE	CHECKED BY	DATE