

**Table I**

**PLUG VALVES FOR SERVICE HEAD INSTALLATION**

Manufacturer	Catalog or Figure Number	Nominal Size
Dresser Industries, Inc.	175 GTO – 0004 - 161	3/4"
	175 GTO – 0011 - 161	1"
	175 GTO – 0012 - 161	1¼"
	175 GTO – 0013 - 161	1½"
	175 GTO – 0006 - 161	2"
Nordstrom Valves, Inc. ***	142 T	3/4", 1", 1¼ ", 1½ "
	143 T	2"* , 3"* , 4"*
	149, 169	3"* , 4"*
Walworth Company ****	1796 T	6", 8", 10", 12"
	1797 F	1", 1¼", 1½", 2"
	1707 F, 1727 F	3"
		6", 8", 10", 12"

NOTE: Wrench operated valves up to and including 4-inches must be of tamperproof construction.

\* For design operating pressures not exceeding 1 psig.

\*\* For design operating pressures greater than 1 psig.

\*\*\* Rockwell equipment of the specified catalog or figure number is acceptable.

\*\*\*\* Figure 1796 and 1979, the manufacturer recommends changing existing non-tamperproof cap screw and replacing them with tamperproof cap screws at field site. The vendor's change out recommendation instructions must be followed completely in order to maintain material warranty.