







Y-9580-03

**REVISIONS**

NO. 1	DATE 1-26-70	BY	REVISION
2	1-26-70		ADDITIONAL WORK AND PIPING
3	1-26-70		ADDITIONAL WORK AND PIPING
4	1-26-70		ADDITIONAL WORK AND PIPING
5	1-26-70		ADDITIONAL WORK AND PIPING
6	1-26-70		ADDITIONAL WORK AND PIPING
7	1-26-70		ADDITIONAL WORK AND PIPING
8	1-26-70		ADDITIONAL WORK AND PIPING
9	1-26-70		ADDITIONAL WORK AND PIPING
10	1-26-70		ADDITIONAL WORK AND PIPING



ITEM	80 OR 170		250		250AL	
	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET
1	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
2	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
3	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
4	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
5	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
6	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"

ITEM	500		1000		1000AL	
	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET
1	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
2	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
3	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
4	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
5	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
6	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
7	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
8	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"

NOTES:  
 1) FOR REPLACEMENT OF EX. GAS. INC. 150A.  
 2) ALL PIPE AND FITTINGS TO BE BLACK GALVANIZED IRON UNLESS INDICATED OTHERWISE.

**ADAPTATION OF EXISTING GAS METER PIPING INSTALLATION FOR CHANGE IN METER SIZE**  
 SHEET 1 OF 2

CONSOLIDATED EDISON COMPANY OF N.Y., INC.  
 GAS ENGINEERING DEPT.

DATE 4/12/70 DWN. NO. **EO-9580-A** REV. **8**  
 LAST REV. 8/24/70 SHEET 1 OF 8

Y-0850-03

**REVISIONS**

1	REVISED	1-22-71	D
2	REVISED	1-22-71	D
3	REVISED	1-22-71	D
4	REVISED	1-22-71	D
5	REVISED	1-22-71	D
6	REVISED	1-22-71	D
7	REVISED	1-22-71	D
8	REVISED	1-22-71	D
9	REVISED	1-22-71	D
10	REVISED	1-22-71	D
11	REVISED	1-22-71	D
12	REVISED	1-22-71	D

APPROVED BY: [Signature]



DATE: 1-22-71

BY: [Signature]

SCALE: AS SHOWN

PROJECT: [Project Name]

SHEET NO. 2 OF 2



ITEM	DESCRIPTION	500		1000	
		TYPE 80-B	TYPE 100-B	TYPE 80-B	TYPE 100-B
1	EXISTING NIPPLE	2"	2"	2"	2"
2	REDUCING COUPLING OR COUPLING *	2" x 1 1/2"			
3	METER BAR	2" x 1 1/2"			
4	CL. TO CL. OF METER BAR TAPPINGS	15"	15"	15"	15"
5	NIPPLE	1 1/2"	1 1/2"	1 1/2"	1 1/2"
6	ELBOW 90°	1 1/2"	1 1/2"	1 1/2"	1 1/2"
7	STREET ELBOW 90°	1 1/2"	1 1/2"	1 1/2"	1 1/2"
8	NIPPLE	1 1/2"	1 1/2"	1 1/2"	1 1/2"
9	SWIVEL	1 1/2"	1 1/2"	1 1/2"	1 1/2"
10	AMOUNT OF SWIVEL OFFSET	1"	1"	1"	1"
11	SWIVEL CAP	1"	1"	1"	1"
12	REDUCING COUPLING	1" x 1/2"	1" x 1/2"	1" x 1/2"	1" x 1/2"

TABLE A

EXISTING METER	EXISTING DIMENSION "O"
TYPE 25C	25 3/4"
TYPE 40C	28 3/4"
TYPE 80C	34 3/4"
TYPE 100A	31 3/4"
TYPE 200B	40" OR 48"
TYPE 500B	40" OR 48"
NO. 4 1/2" ENCO	48"
NO. 5 ENCO	48"
CLASS 3000	48"
CLASS 6000	48"

METER


1) FOR REPLACEMENT OF 25C, 40C, 80C, 100A, 200B AND CLASS 3000. SEE 10-1172-8

2) ALL PIPE AND FITTINGS TO BE STANDARD BLACK STEEL. EXCEPT SWIVEL, SWIVEL CAP, SWIVEL CAP NUTS AND WASHERS OTHERWISE.

METER CLASS OR SIZE TO BE INSTALLED

EXISTING INSTALLATION PIPED FOR METER

ITEM	DESCRIPTION	250	500	1000
1	EXISTING METER VALVE	3" OR 4"	3" OR 4"	3" OR 4"
2	BUSHING-STUB	3" x 1" OR 4" x 1"	3" x 1" OR 4" x 1"	3" x 1" OR 4" x 1"
3	SIZE TO SUIT VALVE	1" x 2"	1" x 2"	1" x 2"
4	NIPPLE	1"	1"	1"
5	LOCK WING COCK	1"	1"	1"
6	METER BAR	1" x 1/2"	1" x 1/2"	1" x 1/2"
7	CL. TO CL. OF METER BAR TAPPINGS	11" OR 12"	11" OR 12"	11" OR 12"
8	ELBOW 90°	1"	1"	1"
9	PIPE (LENGTH TO SUIT)	1"	1"	1"
10	SWIVEL	1"	1"	1"
11	AMOUNT OF SWIVEL OFFSET	1"	1"	1"
12	SWIVEL CAP	1"	1"	1"



ADAPTATION OF EXISTING GAS METER PIPING INSTALLATION FOR CHANGE IN METER SIZE

SHEET 2 OF 2

CONSOLIDATED EDISON COMPANY OF N.Y., INC.

GAS ENGINEERING DEPT.

DATE: 4-12-80

LAST REV. 1/24/78

DWG. NO. EO-9580-A

REV. 8

SHEET 2 OF 2

THIS DRAWING SUPERCEDES DRAWING EO-7123-C