





C-9186-03  
 REVISIONS  
 3  
 CHD STL GIES (FORM 2) TO SC-4-6 STL COVER ADD DRAIN  
 M.P. 1-23-66  
 SECTION NO. 1474  
 CORRECTED STOCK NO. FOR FRAME & COVER.  
 D.R. 6-14-67  
 PULLMAN 12/27/65  
 UPDATED SPECS. 11-24-78  
 MADE OBSOLETE 3-31-88



**SPECIFICATIONS:**  
 ALL REINFORCEMENT BARS SHALL BE #4 DEFORMED, BILLET STEEL AND SHALL CONFORM TO A.S.T.M. SPEC. DES. A-615, GRADE 40.  
 WIRE TIE ALL BARS AT CONTACT POINTS. LAYOUT TO SPECIFY CONDUIT LOCATIONS.  
 REINFORCING BARS TO BE BENT AROUND OPENINGS WHERE REQUIRED.

NOTE- THIS TYPE OF BOX IS NON-STANDARD AND NOT FOR GENERAL USE. IT IS AUTHORIZED FOR USE ONLY ON SPECIAL APPLICATIONS; AT LOCATIONS WHERE SUB-SURFACE CONDITIONS PREVENT THE OBTAINING OF THE FULL DEPTH REQUIRED FOR THE INSTALLATION OF A STANDARD BOX.

FIELD MANUALS  
 NO. 11 SUBWAY  
 CONSTRUCTION  
 SECT 3 BOXES, MHS  
 & VAULTS  
 NO. 16 SERV. INSPECT.  
 CONTROL  
 SECT 2 SERV. BOXES  
 AND END BOXES  
 NO. 17 SURVEY  
 SECT 3 BOXES,  
 MANHOLES & VAULTS  
 NO. 4 SERV. INSTALL  
 SECT 8 BOXES, DIST.  
 AND SERV.  
 CONSTR. STDS.  
 MANUAL NO. 3  
 SECTION NO. 20  
 BOXES, DIST.  
 AND SERVICE

**BILL OF MATERIAL.**

ITEM	QUAN	DESCRIPTION	DWG. OR SPEC.	STOCK NO.
1	1	5-3 FRAME	EO-8835-B	003-213B
2	3	SC-4-6 STEEL COVER	EO-12428-B	003-6210
3	AS REQ'D.	CONCRETE - CLASS II	EO-100B	
4	AS REQ'D.	72" x 54" x 1/2" STEEL PLATE		
5	AS REQ'D.	CEMENT MORTAR	EO-100167	

**REINFORCEMENT SCHEDULE**

ITEM	LOCATION	QUAN	LENGTH	SHAPE
8	SIDE WALLS	AS REQ'D.	6'-10"	STRAIGHT
9	ALL WALLS	14	VARIABLE	STRAIGHT
10	END WALLS	AS REQ'D.	5'-0"	STRAIGHT
11	FLOOR	6	5'-0"	STRAIGHT
12	FLOOR	4	6'-10"	STRAIGHT

**OBSELETE**  
 Date 3-31-88  
 SUPERSEDED BY EO-14819-C

**FIELD CONSTRUCTED DISTRIBUTION BOX TYPE 5-3C FOR SPECIAL APPLICATIONS**  
 CIVIL ENGINEERING DEPT  
**CONSOLIDATED EDISON COMPANY OF N. Y., INC.**  
 DATE 9-30-59  
 LAST REV. 3-31-88  
 DWG. NO. EO-9316-C REV. 6

NO	DATE	REVISIONS	APPROVED	DIV	SIGNATURE	DATE	DRAWN BY	DATE	CHECKED BY	DATE
2	5-25-64	CHD. TITLE, AND NOTE RE NON-STD.	FC				LABOL	9-30-59	H. H. ...	8-6-57
1		UPD. SPEC. REMOVED WLD. FROM IT TO STL. R. ...								