



**CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.
4 IRVING PLACE
NEW YORK, NY 10003**

DISTRIBUTION ENGINEERING DEPARTMENT

**SPECIFICATION EO – 100184
REVISION 13
OCTOBER 2010**

**EFFECTIVE DATE
OCTOBER 1, 2010**

**PURCHASE RECOMMENDATION FOR
PAINT USED IN 460-VOLT NETWORK PROTECTOR
COMPARTMENTS WITHIN BUILDINGS**

FILE: PURCHASE AND TEST MANUAL NO. 6, SECTION 6

TARGET AUDIENCE	DISTRIBUTION ENGINEERING REGIONAL ENGINEERING
NESC REFERENCE	ALL SECTIONS

TABLE OF CONTENTS

1.0	SCOPE	3
2.0	AIR POLLUTION	3
3.0	MATERIAL	3

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page
EO-100184	Rev. 13	Oct. 2010	10/01/2010	2007-2008 Consolidated Edison Co. of New York, Inc.	2/3
Filing Information		Purchase and Test		Manual No. 6, Section 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](http://distribution) or <http://distribution>, for the current version prior to use.

1.0 SCOPE

This Purchase Recommendation covers paint to be used on concrete block walls, poured concrete walls, ceilings and floor of 460-volt network protector compartments within buildings. Surface preparation and paint application shall conform to Construction Standards Specification EO-1191.

2.0 AIR POLLUTION CONTROL CODE

The paint system covered by this specification shall comply with Title 6 of the New York Code of Rules and Regulation – Part 205 Architectural Surface Coatings.

3.0 MATERIAL

The following products have been approved (see note):

- | | | |
|----|---|--|
| a) | Eastern Paint Industries
1851 Flatbush Avenue
Brooklyn NY 11210 | CE Vault White
CE Vault Gray |
| b) | Sherwin Williams | Loxon Surfacer A24W200 White
Loxon Coating A24W351 Shell Gray
[MAB 8-10] |

NOTE: The Material Safety Data Sheets must accompany each and every order delivered. A copy of the MSDS must be on every job site.

Kevin P. Oehlmann (Signature on File)
Kevin P. Oehlmann
Section Manager
Distribution Engineering Section
Distribution Engineering Department

Kishan Patel

<u>REVISION 13:</u> Confirmed list of approved vendors. Updated approved product list. General revision.	<u>FILE:</u> Purchase and Test Manual No. 6, Section No. 6 - Coatings
--	---

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page
EO-100184	Rev. 13	Oct. 2010	10/01/2010	2007-2008 Consolidated Edison Co. of New York, Inc.	3/3
Filing Information		Purchase and Test		Manual No. 6, Section 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](http://distribution) or <http://distribution>, for the current version prior to use.