





**REVISIONS**

R.RAEBIGER 04/29/02 1

THIS DRAWING HAS BEEN REDRAWN INTO THE AUTOCAD SYSTEM. RELEASE FOR RECORD. GJC 12/16/93 QA'd AR 10/99




NOTE  
MAXIMUM NUMBER OF RECESSES SHOWN HERE. SELECT ONLY THOSE REQUIRED FOR SPECIFIC LAYOUT




**SECTION A-A**

**SECTION B-B**



STRUCTURAL STEEL SHALL CONFORM TO ASTM SPEC. DES. A 36. REINFORCING RODS SHALL CONFORM TO ASTM SPEC. DES. A 615, GR 60.



**PLAN**

16	END WALLS	(10) 4'-2"	41.66'
15	SIDE WALLS	(10) 5'-2"	51.66'
14	SIDES VERTICAL	(16) 4'-6"	72.0'
13	CORNERS	(4) 1'-3"   1'-9"	11.0'
12	FLOOR	(4) 1'   5'   1'	28.0'
11	FLOOR	(6) 1'   4'   8'	36.0'
10	TACK WELDED TO STEEL IN ROOF	2.6 SQ. FT.	No. 13 GA. EXP. METAL REINF. 0.8 LB. PER SQ. FT.
9		2.8 SQ. FT.	
8		5.8 SQ. FT.	
7	ROOF	10 SQ. FT.	No. 4 GA. WIRE FABRIC 4" x 4" MESH .85 LB. PER SQ. FT.

2 1/2" x 3'-2 5/8" LG.	2.08#
2" x 4'-2" LG.	2.24#
4" x 4'-2" LG.	4.48#
No. 4 GA. WIRE FABRIC 4" x 4" MESH .85 LB. PER SQ. FT.	8.5#

REINF. RODS	90.36#
STRUCT. STEEL	139.00#
WIRE MESH	17.30#
<b>TOTAL</b>	<b>246.66#</b>

ITEM No.	LOCATION	QUANTITY	KIND	WEIGHT
----------	----------	----------	------	--------

**REINFORCEMENT SCHEDULE**

ITEM No.	QUANTITY	DESCRIPTION	DWG. OR SPEC.
19	8	8" CABLE HANGER	EO-2086-C
18	4	4 1/2" CABLE HANGER	EO-2086-C
17	3	FOUR SLOT RACK PLATE	EO-2086-C
6	2	L 2 1/2 x 2 1/2 x 1/4 - 3'-2 5/8" LG.	
5	2	4" WF 113 - 4'-4" LG.	
4	8	3/8" INSERT FOR CABLE RACK PLATE	EO-100, 133
3	1	MANHOLE COVER Q-8-V OR APPROVED EQUAL	EO-9358-C
2	1	MANHOLE FRAME Q-8-7 OR APPROVED EQUAL	EO-9360-C
1	1.53 CU.YD.	CONCRETE - CLASS B - N.Y.C. CODE	EO-1008

**BILL OF MATERIAL**

REFERENCE DRAWING: ENTRANCE RECESS EO-9508-C

**CUSTOMER PROPERTY LINE BOX  
CONCRETE - FIELD CONSTRUCTED  
4'-6" x 3'-6" x 4'-0" DEEP**

**CONSOLIDATED EDISON COMPANY OF N.Y., INC.  
DISTRIBUTION ENGINEERING DEPT**

DATE 04/24/02 DWG. NO. EO-10262-C REV. 1  
LAST REV. 10/99

FIELD MANUALS  
No. 11 SUBWAY CONSTRUCTION  
SECTION 3 BOXES MANHOLES & VAULTS  
No. 18 SERVICE INSPECTION AND CONTROL  
SECTION 2 SERVICE BOXES AND END BOXES  
No. 17 SURVEY  
SECTION 3 BOXES MANHOLES & VAULTS  
No. 4 SERVICE INSTALLATION  
SECTION 1 SERVICES UNDERGROUND  
CONSTRUCTION STD'S. MANUAL No. 3  
SECTION 36 SERVICES & UNDERGROUND