





EO-13079-C

REVISIONS



McQuay 5-11-61	0
A. NOEL 07.30.09	1
UPDATED MANUFACTURERS INFORMATION.	
JDV. 07.28.09	



6 LENGTH TO BE DETERMINED IN FIELD SEE NOTE 1.




1 INSULATED BUS ASSEMBLY



2 BRACKET MATERIAL: #14 GAGE H.D. COPPER OR BRASS

3 UNINSULATED BUS ASSEMBLY



4 BRACKET MATERIAL: #14 GAGE H.D. COPPER OR BRASS

NOTES:

- 1- ITEM 6-BEND FOR SNUG FIT AROUND BUS. DRILL 1" AWAY FROM BUS TO ALLOW ITEM 2 TO BE TURNED.
- 2- WHEN CLEARANCE FROM OTHER OBJECTS PERMITS, ITEM 2 OR ITEM 4 MAY BE TURNED TO PROJECT ITEM 8 AWAY FROM BUS FOR GREATER LUMINATION.
- 3- THESE ASSEMBLIES MAY BE MOUNTED ON EITHER VERTICAL OR HORIZONTAL BUS SECTION.

REFERENCE:
SPEC. EO-2022

CONSTRUCTION DEPT.
FIELD
MANUAL #16
SECTION:
SERVICES,
ELECTRIC

CONSTRUCTION SIDS
MANUAL #5
SECTION:
ELECTRIC

SYSTEM
OPERATION
MANUAL NO.5
ELECTRIC
SECTION

ITEM NO.	QUAN.	DESCRIPTION
9	1	#10-32 X 1" LG. RH.M.S., FL. WASH., LCK. WASHER & NUT
8	4	NEON-TUBE, GLOW TUBE TYPE "R" STOCK NO. 595-0027
7	4	MOUNTING CLIP, GLOW TUBE PRODUCT CODE: 050-1009
6	1	#22 GAGE COPPER OR BRASS STRAP 2"W.
5	5	#10-32 X 3/8" LG. RH.M.S. WITH FL. WASH., LCK. WASH. & NUT

NEON TUBE INDICATOR
(BUS INSTALLATION)

CONSOLIDATED EDISON COMPANY OF N.Y., INC.

DATE 4-21-67
LAST REV. 07.28.09

DWG. NO. EO-13079-C REV. 1

NO.	DATE	REVISIONS	APPROVED	FOR APPROVAL	DIV.	SIGNATURE	DATE	DRAWN BY	DATE	CHECKED BY	DATE
					TRACED BY		DATE	1/2" SCALE		1 INCH	
					APPROVED						
					DESIGN ENGINEER F. J. DiPaola OUTSIDE PLANT ENGINEER DATE 5/14/67						

6/15/67