







C-29201-03

REVISIONS

1
THIS DRAWING HAS BEEN REDRAWN INTO THE AUTOCAD SYSTEM. RELEASE FOR RECORD.
GJC 12/16/93



ITEM No.	LOCATION	QUANTITY	KIND	WEIGHT
16	END WALLS	(10) 4'-2"	41.66'	
15	SIDE WALLS	(10) 5'-2"	51.66'	
14	SIDES VERTICAL	(16) 4'-6"	72.0'	
13	CORNERS	(4) 1'-3" x 1'-6"	11.0'	
12	FLOOR	(4) 1' x 5' x 1'	28.0'	
11	FLOOR	(6) 1' x 4' x 1'	36.0'	
10	TACK WELDED TO STEEL IN ROOF	2.6 SQ. FT.	No. 13 GA. EXP. METAL REINF. 0.8 LB. PER SQ. FT.	2.08#
9		2.8 SQ. FT.		2.24#
8		5.6 SQ. FT.		4.48#
7	ROOF	10 SQ. FT.	No. 4 GA. WIRE FABRIC 4' x 4' MESH .85 LB. PER SQ. FT.	8.5#



FIELD MANUALS No. 11 SUBWAY CONSTRUCTION SECTION 3 BOXES MANHOLES & VAULTS No. 16 SERVICE INSPECTION AND CONTROL SECTION 2 SERVICE BOXES AND END BOXES No. 17 SURVEY SECTION 3 BOXES MANHOLES & VAULTS No. 4 SERVICE INSTALLATION SECTION 1 SERVICES UNDERGROUND
CONSTRUCTION STD'S. MANUAL No. 3 SECTION 36 SERVICES & UNDERGROUND

ITEM No.	QUANTITY	DESCRIPTION	DESCRIPTION	DWG. OR SPEC.
19	8	8' CABLE HANGER	ED-2086-C	
18	4	4 1/2" CABLE HANGER	ED-2086-C	
17	3	FOUR SLOT RACK PLATE	ED-2086-C	
6	2	L 2 1/2 x 2 1/2 x 1/4 - 3'-2 5/8' LG.		
5	2	4' WF 113 - 4'-4' LG.		
4	8	3/8" INSERT FOR CABLE RACK PLATE	ED-100, 133	
3	1	MANHOLE COVER 0-8-V OR APPROVED EQUAL	ED-9358-C	
2	1	MANHOLE FRAME 0-8-7 OR APPROVED EQUAL	ED-9360-C	
1	1.53 CU. YD.	CONCRETE - CLASS B - N. Y. C. CODE	ED-1008	

REINFORCEMENT SCHEDULE	WEIGHT	TOTAL
2 1/2" x 3'-2 5/8' LG.	2.08#	
2" x 4'-2" LG.	2.24#	
4" x 4'-2" LG.	4.48#	
4' x 4'-2" LG.	8.5#	
REIN. RODS	90.36#	
STRUCT. STEEL	139.00#	
WIRE MESH	17.30#	
TOTAL	246.66#	

REFERENCE DRAWING: ENTRANCE RECESS ED-9508-C
CUSTOMER PROPERTY LINE BOX CONCRETE - FIELD CONSTRUCTED 4'-6" x 3'-6" x 4'-0" DEEP
CONSOLIDATED EDISON COMPANY OF N. Y. INC.
DATE 04/24/62 DWG. ED-10262-C REV. 1
LAST REV. 12/16/93 NO.

COMPUTER GENERATED DRAWING NOT TO BE HAND REVISED

DIV.	SIGNATURE	DATE	DRAWN BY	DATE	CHECKED BY	DATE
G & E	J. J. ROSE	05/01/66	N. GARRELAND	04/24/61	B. HAVILAND	04/28/62
			DISCIPLINE CODE	SCALE 3/4" = 1'-0"		
			APPROVED			
			CHIEF DESIGN ENGINEER DATE			
			L. J. CAVAGNET			
			DIST. STRUCT. ENGR. DATE			