

8-98991-03

**REVISIONS**  
 C.FISHER 4/24/87 3  
 REDRAWN, NEW BILL OF MATERIAL.  
 CM. 4/6/87 JP  
 C.FISHER 3/28/88 4  
 ADDED STOCK NOS. TO ITEMS 9, 16, 23 AND 27. CHG'D STOCK NOS. FOR ITEM 4, 9, 16, 17, 18, 23 AND 27.  
 J.P. 3/24/88 JP  
 UPDATED DWG. ADDED NOTE (c).  
 C.W. 9/21/95  
 HBA/BOVIN 4/7/99  
 UPDATED DWG. AND ADDED NOTE (a) & (e).  
 C.W. 4/7/99

ITEM NO.	DESCRIPTION	STOCK NO.	LOW PRESSURE INSTL. SIZE	HIGH PRESSURE INSTL. SIZE	SPEC. OR DWG. NO.
28	BAR, METER, 2" X 2" X 1 1/2" W/10° CC, CL. 1000	339-0705			
27	PLUG, METER NUT (FOR TESTING SEE NOTE K) 20 LT. (CL. 250TC) 30 LT. (CL. 500TC)	339-0655 339-0663	X	X	
26	CAULKING COMPOUND WALL SLEEVE, SCH. 40 P.V.C. OR STEEL PIPE (SIZE AS REQ'D.) 2" (SIZE AS REQ'D.) 3" 4"		X	X	
25	VALVE, PLUG, WHERE REQ'D. BY LOCAL MUNICIPALITY (SIZE AS REQ'D.) 1" (CL. 250TC) 1 1/2" (CL. 250TC OR 500TC) 2"		X	X	*
24	PLUG, PIPE, STEEL, HEXAGON SOCKET 1/8"	339-0648	X	X	
23	ELBOW, 90°, RED., MI., 150LB. 2" X 1 1/2"	332-9323		X	ANSI B16.3
22	ELBOW, 90°, RED., MI., 150LB. 1 1/2" X 1" (CL. 250TC) 1 1/2" X 1 1/4" (CL. 500TC) 2" X 1 1/4"	332-1288 332-1296 336-7901	X	X	ANSI B16.3
21	NIPPLE, STEEL 2" X 3" SCH. 80 SEE NOTE (d) PIPE, STEEL (SIZE AS REQ'D.) 1 1/2" 2"	330-1314 320-1753 320-1719 320-0367		X	ASTM A53 GR B
20	SWIVEL, CAP, MI. 20LT. (CL. 250TC) 30LT. (CL. 500TC) 60LT.	339-0218 339-0226 339-0234	X	X	*
19	SWIVEL, MI. 20LT., 1" OFFSET, 3 1/2" LG. (CL. 250TC, FOR 6 1/2" CENTER BAR) 20LT. STRAIGHT (CL. 250TC, FOR 6" CENTER BAR) 30LT. X 20LT., 1" OFFSET, 3 3/4" LG. (CL. 500TC) 1 1/2" X 60LT.	339-0333 NON-STOCK 339-0564 339-0408	X	X	*
18	SUPPORT BRACKET 1 1/2" X 14" ANGLE IRON W/U-BOLT	339-0630	X	X	*
17	LOCK-WING STOP 1"	374-0681	X	X	*
16	ELBOW, MI., 150LB. 1" X 1"	332-1163	X	X	ANSI B16.3
15	TEE, MI., 150LB. 1" X 1" X 1"	332-1445	X	X	ANSI B16.3
14	ELBOW, 90°, MI., 150LB. 1" X 1" 2" X 2"	332-0983 332-1049	X	X	ANSI B16.3
13	NIPPLE, STEEL 1" X 20" 2" X 6 1/2" 2" X 9"	330-4268 330-3633 330-3682	X	X	ASTM A53 GR B
12	NIPPLE, STEEL 1" X 2" (CL. 250TC) 1 1/4" X 2" (CL. 500TC) 1 1/4" X 12"	330-2742 330-2992 330-3245	X	X	ASTM A53 GR B
11	BAR, METER, CMC, W/INSULATED UNION (SWIVELS NOT REQ'D.) 1" X 1" X 20LT. (FOR CL. 250TC) 1" X 1 1/4" X 30 LT. (FOR CL. 500TC) ALTERNATE METER BAR (SWIVELS REQ'D.) 1" X 1" X 1" (CL. 250TC OR CL. 500TC)	339-0506 339-0622 NON-STOCK	X	X	*
10	METER ELBOW, 90°, STEEL 1" X 6" X 8"	SEE NOTE ( ) 331-2360		X	ASTM A53 GR B
9	NIPPLE, STEEL 1" X 5"	330-0936		X	ASTM A53 GR B
8	NIPPLE, STEEL 1" X 3/4" X 7"	330-4441		X	ASTM A53 GR B
7	NIPPLE, STEEL, TOE (SEE NOTE g) 1" X 3" 1 1/4" X 4" 1 1/2" X 3" 2" X 10"	330-0876 330-1058 330-3302 330-1447	X	X	ASTM A53 GR B
6	COUPLING, COMPRESSION, INSULATED, DRESSER STY. 90 SEE NOTE (f) 2" COUPLING COMPRESSION CONDUCTIVE DRESSER, STY. 65 2"	337-0582 337-4113		X	* G-100, 285
5	METER ELBOW, 90°, STEEL, THD, BOTH ENDS 1" X 4 1/2" X 14" SEE NOTE ( ) MALE, ADAPTER, INSULATED, DRESSER STY. 90 SEE NOTE (f) 1" 1 1/4"	339-0614 337-5904 337-5912	X	X	*
4	COUPLING, COMPRESSION, RED., INSULATED SEE NOTE (f) 1 1/4" X 1" 1 1/2" X 1"	337-7785 337-7777	X	X	*
3	COUPLING COMPRESSION, CONDUCTIVE 1" DRESSER STY. 65 1 1/4" X 1" DRESSER STY. 65 COUPLING, COMPRESSION, CONDUCTIVE, REDUCING 1 1/4" X 1" 1 1/2" X 1"	337-4097 337-4060 337-5060 337-2688	X	X	* G-100, 285
2	GAS SERVICE REGULATOR GAS METER CLASS		250TC-500TC	1000TC 1" X 1" X 3/4" 250TC-500TC 1000TC	PROCEDURE G - 48

FOR NOTES SEE INSTALLATION DRAWING EO-16585-A SHEET 1 OF 2

**INSTALLATION OF METER PIPING  
FOR CLASS 250-1000TC DIAPHRAGM  
GAS METERS - OUTDOORS**

**CONSOLIDATED EDISON COMPANY OF N. Y. INC.**  
CENTRAL GAS OPERATIONS DEPARTMENT

DATE 12/8/83 DWG. EO-16585-B REV. 8  
LAST REV. 4/7/99 NO. SHEET 2 OF 2

\*SEE "REQUIREMENTS FOR GAS SERVICE INSTALLATIONS" BOOKLET

METERING SPECIFICATIONS AND PROCEDURES VOLUME NO. 3

FOR APPROVAL	DIV	SIGNATURE	DATE	DRY BY DATE	CHECKED BY DATE