



CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.
31-01 20th Avenue Bldg. 136
Astoria, NY 11105

**ELECTRIC METER SHOP
DEPARTMENT**

**METER ENGINEERING SPECIFICATION – 350
REVISION 7**

**High Tension Metering Installations General
Requirements**

PREPARED BY:	Michael Parobek & Adam Miller
TARGET AUDIENCE	ELECTRIC OPERATIONS -Meter & Test CUSTOMER OPERATIONS – SI METER SERVICES ELECTRIC METER SHOP, ENERGY SERVICES
REVIEWED BY:	METER ENGINEERING
NESC REFERENCE	Sec. 9, 10, 11, 12, 15, 16, 17, 18, 44
FILING:	FIELD MANUAL NO. 16 – SEC 3 & NO. 4 – SEC 6
APPROVER	Charles Feldman
	SIGNATURE/DATE Signature on File – April 3, 2024
EFFECTIVE DATE:	April 3, 2024

Table of Contents

1.0	Scope	3
2.0	Application	3
3.0	General.....	3
4.0	Mounting Facilities for Watthour and Metering Devices.....	3
5.0	Mounting Facilities for Instrument Transformers.....	3
6.0	Primary Wiring of Current and Potential Transformers	4
7.0	Secondary Wiring of Current and Potential Transformers	4
8.0	Grounding.....	5
9.0	Fusing of Potential Transformers.....	6
10.0	Customer's Meter and Protective Devices.....	7
11.0	Meters and Devices for High Tension Metering.....	7
12.0	Meter Communication Module Location	8
13.0	Metal – Clad and Metal – Enclosed Switchgear	9
14.0	References	11
15.0	Revision Summary	12
16.0	Attachments.....	12
	EXHIBIT A – Inspection Guidelines List for High Tension Installations	14
	EXHIBIT B – Typical Metering Layout of High – Tension Service	20

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 2/21
ME3 – 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

1.0 Scope

This Specification supplements EO Specification No. EO-4035 and No. EO-2022, and covers the general requirements for wiring, grounding and mounting facilities for meters and instrument transformers used in revenue metering of electric energy and demand on high tension installations. This specification encompasses any installation that is projected to have a maximum demand (delivered by the customer or received from the customer) that is less than 9MVA.

2.0 Application

This specification applies to all regions involved with metering of High-Tension Services (services above 600V).

3.0 General

Instrument transformer wiring, and installation details shall be in accordance with the reference specifications provided by the Company.

4.0 Mounting Facilities for Watthour and Metering Devices

The customer shall furnish and install meter mounting facilities which have Company approval. A list of approved meter mounting equipment is contained in the Company booklet "Requirements for Electric Service Installations" under section "Approved Electric Service Equipment". The installation of this equipment shall be made in accordance with the Company booklet "General Instructions Governing Work on System Electrical Equipment ". Panel mounting may be used in metal-clad and metal enclosed switchgear in accordance with the requirements of Section 13 when wall mounting of the equipment is impracticable. The Company will furnish and install meters and metering devices.

5.0 Mounting Facilities for Instrument Transformers

The customer shall furnish and install mounting facilities for the Company's metering transformers. These transformers will be furnished by the Company and shall be installed by the customer on initial installation and upon subsequent alteration to the main cable or bus circuit. All instrument transformer mounting facilities are subject to approval by the Company. The customer shall submit drawings showing space allocation and cubicle configuration for the metering transformers for Company approval. Metering transformers may be installed in metal-clad and metal enclosed switchgear in accordance with Section 13.

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 3/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	

Filing Information Field Manual

Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

6.0 Primary Wiring of Current and Potential Transformers

- 6.1.** The customer shall make the primary connections to the current and potential transformers. All connections to the primary terminals of current transformers shall be insulated for the line-to-line voltage. Removable bushing type insulators may be used. All primary terminal connections shall be insulated. All insulation material used shall be rated for the line-to-line primary voltage. Revenue metering transformers are subjected to the high potential proof test in accordance with Spec. EO-2022 and EO-4019.
- 6.2.** Current and potential transformers shall be installed with the polarity markings in accordance with the Company's wiring diagrams.
- 6.3.** Primary connections of the potential transformers shall be made on the line side of the current transformers. All primary potential connections, requiring cables, shall use approved 1/C Copper EPR insulation/jacket non-shielded jumper cables No. 6 (minimum) or No. 2 (maximum) AWG and be insulated for the line-to-line voltage.
- 6.4.** The customer shall clearly identify and mark Phase A, B & C PTs & CTs in the transformer enclosure.
- 6.5.** The customer shall identify Phase A, B & C PTs & CTs and mark associated H2 and X2 terminals on the wiring diagrams.

7.0 Secondary Wiring of Current and Potential Transformers

- 7.1.** The customer shall furnish and install all wiring and conduit. The material used for the insulation and jacket of the wiring must be environmentally acceptable.
- 7.2.** The current and potential transformer secondary wiring shall be in rigid conduit or in electrical metallic tubing, separate from all other wiring. The instrument transformer secondary wiring of one meter shall not be run in the same conduit with the wiring of another meter. It is preferable that current and potential transformer secondary wiring be in a single conduit for each meter. If two conduits per meter are used, the current transformer secondary wiring shall be in one conduit and the potential transformer secondary wiring shall be in the other conduit. Color-coded wires or multiple-conductor cable, according to N.E.M.A. color coding of control cables, shall be used for current and potential transformer secondary wiring. Color-coded multiple-conductor cable shall consist of No. 10 AWG stranded copper wire. The material used for the wire insulation must be environmentally acceptable. Suitable lugs of the closed loop type shall be furnished and installed by the customer for connection of stranded wire to the

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 4/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

meter connection block. If multiple-conductor cables are not used, the current and potential transformer secondary wires shall be No. 10 AWG stranded copper.

- 7.3.** For each meter installation, a single wire shall be used from the common secondary neutral connection of the potential transformers to the meter connection block. However, a separate return wire is required between each current transformer and the meter connection block. When lugs are used, they shall be the closed loop type.
- 7.4.** The secondary wiring of current and potential transformers shall be continuous without splices. Intermediate terminal blocks shall not be used without specific Company approval. CT and PT secondary wiring shall not pass through the phasing facility box or other company fuse boxes.
- 7.5.** No. 10 AWG stranded copper wiring to the current and potential transformer secondary wires shall be cut and formed to proper length and shall be identified by the customer. The Company will make final connections to the instrument transformer secondary terminals. Connections to the bottom of the meter connection block shall be made by the customer. The Company will install the watt-hour meter and make the final connection to the meter.
- 7.6.** Current and potential transformers should be located within 25 linear feet of the watt-hour meter. If the distance exceeds 25 feet, the installation is to be referred to the Company for specific approval.
- 7.7.** Placement of the secondary terminal box on the PTs and CTs shall not be arranged to restrict or cause the technician to wedge themselves between the cubical and the instrument transformer for access.
- 7.8.** For legacy instrument transformer enclosures that require instrument transformer replacement, wiring the transformer in reverse (for both primary and secondary side simultaneously) shall be done only when space is limited, usually during non exact replacement scenarios to avoid the situation as per para 7.7.
- 7.9.** Short-circuiting wires and tags on current transformers will be removed by Company forces when making connections to the watt-hour meter.

8.0 Grounding

- 8.1.** The customer shall furnish, install, and connect all ground wires.
- 8.2.** Ground wires shall be continuous without splices or intermediate connections.

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 5/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

8.3. Current and potential transformer secondary neutral terminals shall be connected to the instrument transformer enclosure ground bus as close as possible, using #10 (minimum) AWG stranded copper wire. The current transformer neutral ground wires shall be separate from the potential transformer neutral ground wire. There shall be no other ground connection to the secondary circuits.

8.4. The Instrument transformer (CT & PT) cases shall be electrically confirmed to be connected to the cubicle ground bus through the transformer's base (mount).

8.5. PT & CT secondary neutral wires shall be separately connected to the cubicle ground bus.

8.6. The neutral wire going to the 7- or 10-point block for the meter shall be effectively grounded on the secondary side of the transformer inside of the instrument transformer cubicle. The neutral wires connected to the secondary side of the instrument transformers shall be insulated green copper wire not smaller than No. 10 AWG.

8.7. No additional grounds to the transformer case may be added in addition to the ground specified in sections 8.4 and 8.5.

8.8. Ground connections shall be made to the a-c ground bus or to the primary neutral. For electric service to railway properties, ground connections shall be made to the a-c ground bus, and isolated from the station d-c ground bus. (Refer to Consolidated Edison Co. Specification No. EO-2034).

9.0 Fusing of Potential Transformers

9.1. Potential transformers shall be fused on the primary side for 13 kV and 4 KV Services. All other H.T. Services are not primary fused. The phase conductors of potential transformer secondary wires shall be fused by means of 10 ampere plug fuses mounted in a metal box with a hinged cover provided with facilities to accommodate a meter seal. The fuse box shall be located as near as possible to the potential transformers but not within the transformer compartment and shall be readily accessible. The location shall not be adjacent to exposed high tension equipment so that the fuses may be replaced without hazard, or necessity for de-energizing the high-tension service. Fuse boxes, fuse receptacles, fuses, and all wiring shall be furnished and installed by the customer.

Note: When low-voltage phasing facilities are connected to revenue metering potential transformers, separate secondary fuse facilities shall be provided by the

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 6/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

customer for these devices. These fuses shall be located adjacent to the revenue metering fuses in a separate sealable metal box. The fuses and the fuse box shall be similar to that provided for the revenue meters. Each fuse box shall be identified as to its purpose. (Refer to Consolidated Edison Co. Specification No. EO-3299-D for 3 phase-3 wire feeders and Specification No. EO-3477-D for 3 phase-4 wire feeders).

9.2. Current transformer secondary wiring shall not be fused.

10.0 Customer's Meter and Protective Devices

Generally, the Company's meters shall be connected ahead of the customer's energy consuming devices. Written Company approval is to be obtained when connections for neon indicators, phasing facilities or automatic circuit breaker operation must be installed on the line side of the metering transformers.

Customer's meters or protective devices shall not be connected to the secondary wires of the Company's metering current or potential transformers. The NYCTA has been granted permission to connect a phase-sequence voltage relay 47 device to the metering voltage transformers, by agreement with the Company.

11.0 Meters and Devices for High Tension Metering

11.1. An AMI meter with a standard company prefix (ACT1B or ACT1C) shall be installed to capture KWh and KVarh of load profile data (interval data). A Meter & Test technician shall update the PT and CT serial numbers in Profield and affix an updated label over the standard meter prefix to reflect the service the meter is connected to in accordance with MEP – 70.

11.2. A SAP may be installed to facilitate meter communications. The data is used to calculate the customer's consumption and demand. Pulse outputs and associated wiring are no longer used for demand billing. A SocketAP (Socket Access Point or SAP) is a type of communication device that allows the AMI meter to be part of the mesh network to transmit interval data to the company billing system using wireless cellular technology.

11.3. For a single metering site, Smart Meter (AMI) Communication Requirements shall be found in the Company booklet "Requirements for Electric Service Installations" (blue book) or part of MEP – 1 for AMI communication requirements.

11.4. For a customer location with more than 1 meter installed, refer to Exhibit B.

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 7/21
MES – 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

11.5. If an SAP needs to be mounted within 6' of the meter pan, unmetered power (120VAC) shall be used and wired in rigid conduit and be separate from all other wiring. Refer to the National Electrical Code Table 310-13 for the appropriate wire type designations and specifications. The material of the wire insulation and jacket must be environmentally acceptable. Intermediate splices shall not be used without specific Company approval. However, a Low Voltage SAP is preferable.

11.6. Wiring shall not be installed in areas where the maximum temperature can be more than 60 degrees C (140 degrees F).

11.7. All conduits, wiring, wiring boxes, fuses and mounting facilities shall be furnished and installed by customer. The Company will install meter(s), power transfer relay, and meter communication device with antenna identified in Exhibit B. The Company will make final connections to meter, meter communication device and power transfer relay.

11.8. When pulse (XYZ) contacts are requested by customer, they will be provided at each meter location at a demarcation box furnished and installed by Con Edison. The customer is responsible for all connections and wiring to the customer side of the demarcation boxes.

12.0 Meter Communication Module Location

12.1. In general, the meter communication device should be mounted on the Meter Device mounting plate (Spec MES- 104A) along with the Power Transfer relay assembly. Unmetered power (120VAC) wiring is to be installed from each meter to the power transfer relay assembly.

12.2. The meter communication device should be located so the wiring requirements are at a minimum.

12.3. If the meter communication device requires an antenna, then it should be placed near a window or an area where there is wireless communication.

12.4. There will be applications where the meter communication device will have to be located away from the meter location(s) and the antenna will need to be extended outdoor to provide communications. This will be determined by Distribution Engineering, Electric Meter Shop and M&T personnel based on the site-specific conditions.

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 8/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

13.0 Metal – Clad and Metal – Enclosed Switchgear

13.1. A separate compartment shall be provided for the metering transformers when installed in metal-clad and metal enclosed switchgear. Two separate isolated sections shall be provided in the compartment, one section for the current transformers and the other section for the potential transformers. No equipment, other than the transformers, shall be installed in these isolated sections.

13.2. The Company will specify mounting and overall dimensions of the current and potential transformers. The customer shall provide the mounting facilities for these transformers, and they shall submit drawings of the metering compartment for approval.

13.3. Each section shall be designed so that after proper electrical isolation, the current and potential transformers can be readily installed, maintained, or replaced after the compartment is installed. The minimum electrical clearances between live parts, for indoor installations, are recommended below:

	Phase to Phase	Phase to Grd.
a.	2.4kv 3 phase 4 wire	4.5 in
b.	13kv 3 phase 3 wire	9 in
c.	27kv 3 phase 3 wire	12.5 in
d.	33kv 3 phase 3 wire	12.5 in
		3 in
		6.5 in
		9.5 in
		9.5 in

13.4. In addition, a minimum of 3 inches of clearance is required between each transformer body.

13.5. The transformers are not to be installed on the side walls of the compartment. The transformers shall be a minimum of 6 inches and a maximum of 84 inches above floor level. Each section shall be accessible through hinged doors that are provided with suitable latches and facilities to accommodate standard seals. The doors are to provide access to no equipment other than the metering transformers. There shall be a clear space of at least 3 feet in front of the access doors. For 27 kV and 33 kV services, the oil gauge of the transformers must be installed such that the gauges can be seen and read through the view window of the compartment.

13.6. If aluminum bus is used, tin- or silver-plated terminals shall be provided for connection to the Company's metering transformers. The plating shall be in accordance with ASTM253-53, "Recommended Practice for preparation of and Electroplating on Aluminum Bus". All such connections shall be made with cadmium-coated steel bolts and hex nuts with a Belleville washer under each

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 9/21
MES – 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	
Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site Distribution Engineering or http://distribution , for the current version prior to use.					

nut and each bolt head. The top (convex surface) of each washer is to be marked so as to be conspicuous with the nut and bolt in place. Bolts and nuts shall be tightened until the washers are flat and then backed off 1/8 turn.

13.7. The metering compartment shall be adequately ventilated. If the switchgear is installed outdoors, the compartment shall be rain tight.

13.8. The primary connections of current and potential transformers shall be made in accordance with Section 6.

13.9. The secondary wiring of current and potential transformers shall be in accordance with Section 7, except that where it is impracticable to use conduit within the switchgear, the secondary wiring within the switchgear may be exposed. The wiring shall be properly supported with adequate clearance from high tension busses and equipment. Wiring through partitions shall be installed in conduit nipples fitted with locknuts and bushings, or other means of equivalent protection.

13.10. Grounding shall be in accordance with Section 8.

13.11. The fusing of secondary wiring shall be in accordance with Section 9.

13.12. Meter mounting facilities shall be in accordance with Section 4 and installed away from the switchgear on an adjacent interior wall space or in a weather-proof housing. Where this is not practicable the customer may (after obtaining Company approval) provide a vertical panel in the metering compartment for the Company's meters. The panel shall be in a separate section of the metering compartment completely isolated from any high-tension wiring or equipment. The customer shall furnish and install the panel together with all associated wiring and equipment for the meters (except the meters). The customer shall drill the panel in accordance with information supplied by the Company and shall submit drawings of the meter panel for Company approval. The panel and panel wiring shall be in accordance with the following specifications:

13.12.1. The meter panel shall be recessed at least 11 inches from the front door of the metering compartment and shall be of such design as to permit accessibility to the back of the panel for the purpose of mounting, wiring, and maintaining of the meters and meter devices. If an access door to the rear of the panel is provided, there shall be a clear space of at least 3 feet in the rear of the panel.

13.12.2. If a swinging panel is used, the panel shall be side hinged, and when in operating position there shall be a clearance of at least 11" in the

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 10/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

rear of the panel. There shall be a clear space of at least 3 feet in front of the compartment door providing access to the front of the meter panel. The meter panel shall be used exclusively for the Company's meters and associated devices.

13.12.3. The panel wiring shall be flame-retardant type cover No. 10 AWG stranded copper for watt-hour meter and instrument transformer secondary wiring. The panel wiring shall be firmly attached to the back of the panel. There shall be no exposed wiring on the front of the panel. If the panel wiring is to be connected to other wiring as specified in Sections 7 or 11, terminal blocks may be used for the connections. However, the terminal blocks shall be confined to the meter panel. No other intermediate terminal blocks are permitted. The customer shall wire the panel in accordance with wiring diagram furnished by the Company. The loop wiring between the cubicle wall and the swinging panel shall be of extra flexible construction, No. 10 AWG stranded wire (preferably 104 x 0.01") and shall have sufficient loop length so that the wires will be subject to twisting rather than bending stresses when the swinging panel is opened or closed.

13.12.4. Where required, a flexible braided bond wire or cable, not smaller than No. 4 AWG, copper, shall be installed across the hinge to assure a satisfactorily grounded panel. The hinged panel shall be capable to swing out of at least 90° from its operating position without the possibility of damage to surface mounted meters extending out at least 8 inches from the surface of the panel.

13.12.5. The meter panel shall be at least 30" wide and 60" high and constructed of a suitable material with adequate strength for the meters and devices mounted on it. Clearance slots shall be provided in metal panels for the terminal studs of rear connected meter devices. The top of the panel shall not be more than 84" or less than 72" from floor level. The door or hinged panel providing access to the back of the meter panel shall have facilities to accommodate a meter seal.

14.0 References

[Meter Eng. Spec. No. 166-A](#)

Wiring Diagram for Metering 2400/4150 Volt, 3 Phase, 4 Wire Service using 3 PTs and 3 CTs (for all new installations)

[Meter Eng. Spec. No. 166-B](#)

Wiring Diagram for Metering 2400/4150 Volt, 3 Phase, 4 Wire Service using 2 PTs and 3 CTs (for existing installations)

[Meter Eng. Spec. No. 273-A](#)

Wiring Diagram for Metering 13 kV 3 Phase, 3

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 11/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	

Filing Information Field Manual

Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

	Wire High Tension Service (for existing installations)
<u>Meter Eng. Spec. No. 273-B</u>	Wiring Diagram for Metering 27 kV or 33 kV, 3 Phase, 3 Wire High Tension Service. (for existing installations)
<u>Meter Eng. Spec. No. 273-C</u>	Wiring Diagram for Metering 13 kV 3 Phase, 3 Wire High Tension Service. (for new socket installations)
<u>Meter Eng. Spec. No. 273-D</u>	Wiring Diagram for Metering 27 kV or 33 kV, 3 Phase, 3 Wire High Tension Service (for new socket installations)
<u>Meter Eng Spec. No. 490-C</u>	Transformer Cabinet for 2.4/4 kV service for indoor installations
<u>Meter Eng Spec. No. 491-C</u>	Transformer Cabinet for 2.4/4 kV service for outdoor installations

15.0 Revision Summary

REVISION 7:

- Updated section 8.4.

16.0 Attachments

EXHIBIT A – Inspection Guidelines List for High Tension Installations

EXHIBIT B – Typical Metering Layout of High – Tension Service

Prepared by: Adam Miller

Reviewed by: Meter Engineering

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 12/21
MES – 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	
Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site Distribution Engineering or http://distribution , for the current version prior to use.					

<p>DATES:</p> <p>REVISION 0: January 1952</p> <p>REVISION 1: By HCM – August 1999</p> <ul style="list-style-type: none"> • Complete Revision <p>REVISION 2: By Tom Wong – July 2010</p> <ul style="list-style-type: none"> • Spec has been reformatted to EO-1070 • Revised HT metering requirements in Sections 11 and 12 • Added Exhibit B- typical metering layout for HT Service <p>REVISION 3: By Michael Parobek – June 2016</p> <ul style="list-style-type: none"> • Revised requirements in Sections 11, 12, and 13, Exhibits A and B. <p>REVISION 4: By Costas Magoulas – March 2019</p> <ul style="list-style-type: none"> • Added MES-731A and edited titles in MES-166 and MES-166A in section 14 • Revised requirements in sections 6.3 and 7.2 • Revised Exhibit A section B primary wiring <p>REVISION 5: By Adam Miller – October 2023</p> <ul style="list-style-type: none"> • Revised requirements in sections 7.2, 7.4, 10.0 and 13.12.3, Exhibit A, sections C) Secondary Wiring, D) Meter Wiring and E) Ground Wiring. • Revised Exhibit B “Typical Metering Layout of HT Service”. <p>REVISION 6: By Michael Parobek & Adam Miller – January 2024</p> <ul style="list-style-type: none"> • Updated format to comply with EOP – 5002. • Reformatted Cover Page to include the signature block. • Clarified sections: 6 & 8. • Updated section 11 to reflect AMI metering. <p>REVISION 7: By Adam Miller – January 2024</p> <ul style="list-style-type: none"> • Updated section 8.4. 	<p><u>File:</u></p> <p>Field Manual NO. 16 – SEC 3</p> <p>Field Manual NO. 4 – SEC 6</p>
---	--

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 13/21
MES – 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	
Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site Distribution Engineering or http://distribution , for the current version prior to use.					

EXHIBIT A – Inspection Guidelines List for High Tension Installations

NOTE: The following list of inspection items does not constitute the complete review of the metering switchgear but is to provide an aid for Company inspectors. In general, this list highlights items which have been the source of citations in the past. The customer is required to comply with all Company specifications including MES No. 350 and all applicable National Standards and Environmental rules and regulations.

Items that are checked should be inspected, discussed and if necessary, corrected by the customer.

A) **METERING** ---

- _____ Company meters shall be connected ahead of all customers' energy consuming devices. (Except relay 47 device for NYC Transit Authority substations by agreement).
- _____ Meter mounting equipment shall be of approved manufacture and catalog No. for installation. See approved electric service equipment section of Company rules book.
- _____ Shall be an AMI meter with associated communication device (when communications with the mesh network is not possible with AMI meter alone)

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 14/21
MES – 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

B) PRIMARY WIRING ---

- _____ Instrument transformer wiring checks must be performed to verify the correct specified metering design.
- _____ CT and PT polarity markings are to be in correct relationship.
- _____ PT primary connections shall be on the line side of CTs.
- _____ CT primary terminal requires to be insulated for line-to-line voltage.
- _____ PT primary terminals require to be insulated for line-to-line voltage.

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 15/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

C) SECONDARY WIRING---

- _____ Current transformer secondary wires are not to be fused.
- _____ CT and PT secondary wiring shall not pass through the phasing facility box or other company fuse boxes.
- _____ CT and PT secondary wiring to be in rigid conduit or electrical metallic tubing and separated from all other wiring.
- _____ CT and PT secondary wirings of one meter are to be in one conduit.
- _____ CT and PT secondary wirings shall use color coded wiring as per Company specification.
- _____ CT and PT secondary wiring is to be made by customer from transformers to the bottom of the 7-point or 10-point switch block. (Company will verify wiring prior to energizing)
- _____ Color coded cable shall be No. 10 AWG stranded copper.
- _____ Meter installation - PT common secondary connection to use single wire for return.
 - CT secondary connections to have separated return wires from each CT.
- _____ CT and PT secondary wiring shall be continuous without splices. Intermediate terminal blocks shall not be used without Company approval.
- _____ PT secondary fuse box should be located close to PT but not within PT compartment, readily accessible for fuse replacement without hazard exposing to high tension equipment.
- _____ Wiring to CT and PT secondary connections is to be cut and formed to proper length and identified by the customer by use of color-coded wiring.
- _____ CT and PT secondary wiring must not be tied to high voltage bus for support.

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 16/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

D) METER WIRING ---

- _____ Wiring to the bottom of the meter connection block to be made by the customer. Company will make final connection to the meter only.
- _____ CTs and PTs shall be within 25 linear feet from watt-hour meters.
- _____ Short circuiting wires and tags on CTs will be removed by the Company (Meter Operations).
- _____ Unmetered power (120VAC) wiring by the customer shall be installed in rigid conduit or electrical metallic tubing and shall be separate from all other wiring. Refer to NEC table 310-13 for the appropriate wire type designation and specification for wet or dry location under various conditions.
- _____ All conduits, wiring, fuse boxes, fuses and mounting facilities are to be furnished and installed by the customer.

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 17/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

E) GROUND WIRING ---

- _____ Customer shall furnish, install, and connect all ground wire.
- _____ Ground wire shall be continuous without splices.
- _____ CT and PT secondary connections shall be grounded as close as possible to the transformer using No. 10 AWG insulated stranded copper green wire. CT ground wire is to be separate from PT ground wire.
- _____ Transformer body/cases and meter cases shall be grounded. Meter cases are to be grounded using No. 10 AWG copper wire.
- _____ Ground connections shall be made to the ac ground bus or to the primary neutral. For electric service to railway properties, connection is to be made to ac ground bus and isolated from the station dc ground bus. (refer to Con Ed spec EO-2034)
- _____ Potential transformers shall not be fused on the primary side except for 14,400/120 Volt transformers.
- _____ Ungrounded conductors of potential secondary shall be fused by 10 amperes plug fuses housed in a metal box and have facilities for sealing and be locked and sealed with Company lock and seal.
- _____ Low voltage phasing facilities (Network System Section requirement) shall have separate secondary fuse facilities and be provided in separate sealable fuse boxes.

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 18/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.


F) **SWITCHGEAR ---**

- _____ Switchgear design shall be such that PTs & CTs can be installed, maintained, or replaced easily.
- _____ Metal clad switchgear shall have a separate compartment provided for CT & PT. No other equipment is to be installed in the compartments.
- _____ For indoor installation, the recommended minimum electrical clearances for installing instrument transformers on 4 kV service between live parts is 4.5 inches phase to phase, and 3 inches phase to ground; on 13 kV service between live parts is 9 inches phase to phase and 6.5 inches phase to ground; on 27 and 33 kV service between live parts is 12.5 inches phase to phase and 9.5 inches phase to ground.
- _____ No installation of instrument transformers shall be made on the compartment's sidewalls.
- _____ Switchgear sections shall be accessible through hinged doors with suitable catches and facilities to accommodate standard seals.
- _____ A minimum clear space of 3 feet shall be provided in front of access doors or the door's swing-distance plus 2 feet if the equipment is in public access areas.
- _____ Instrument transformers shall be mounted at minimum distance of 6 inches and maximum distance of 84 inches above the floor.
- _____ Compartment shall be adequately ventilated. If outdoors, the compartment shall be rain tight.
- _____ Secondary wiring shall be properly supported with adequate clearances from high tension buses and equipment.

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 19/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual			Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6	

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

EXHIBIT B – Typical Metering Layout of High – Tension Service



Notes:

- All work shall be done in accordance with Con Edison requirements and the customer shall obtain all necessary approvals from authorities having jurisdiction before service is applied.
- The location of items 2, 3 & 8 shall be determined in the field by a Con Edison representative.
- Con Edison field personnel (Meter & Test) shall perform all final wiring connections to the meters, instrument transformers and associated devices.
- All #10 AWG stranded copper wires (item 2) shall be color coded, continuous, and free of any splices.
- The following specifications shall be adhered to: MES 104-A, MES 273-A, MES 273-B, MES 273-C, MES 273-D and MES 727.

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 20/21
ME3 – 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	
Filing Information	Field Manual				
Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6					

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.

Item	Quantity	Description	Con Edison Specification
***** To be furnished & installed by the customer's contractor, unless indicated by Con Edison *****			
1	1	104A meter pan for meter equipment	MES 104-A (EO-15934-B)
2	1 per feeder (set of instrument transformers)	2 - #10 AWG stranded copper wire in code size conduit for TR 120Vac supply	N/A
3	1 per feeder (set of instrument transformers)	7-point or 10-point meter enclosure from approved manufacturers	Table VII-A in EBB
4	1 per feeder (set of instrument transformers)	Con Edison (CE) to furnish and install AMI CT rated meter	N/A
5	1 per feeder (set of instrument transformers)	#10 stranded copper wire in code size conduit	MES 273-A, MES 273-B, MES 273-C & MES 273-D
6	1	Con Edison (CE) to furnish and install Access Point	N/A
7	1	Con Edison to furnish & install power Transfer Relay	MES 727 (EO-16723-B)
8	1	1" conduit routed to the outside with cap and pull string	N/A

Specification	Revision	Rev Date	Effective Date	Copyright Information	Page 21/21
MES - 350	Rev 7	April 2024	04/03/2024	©1952-2024 Consolidated Edison Co. of New York, Inc.	

Filing Information Field Manual
 Manual NO. 16 – SEC 3 & Manual NO. 4 – SEC 6

Paper copies of procedures and instructions are uncontrolled and therefore may be outdated. Please consult Distribution Engineering Intranet Site [Distribution Engineering](#) or <http://distribution>, for the current version prior to use.