AIRTEK ENVIRONMENTAL CORP.
39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-
3721
AIRTEKENV.COM

Date: 2/10/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/31/2013
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Creddille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:09 TIME OFF: 15:26
TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLO W	STRUCTURE S/PER MM^2*
021014-1353	Inside Work Area Rear of the Electrical Box Downwind B-1	7:09	15:09	3.016	3.016	<17.56
021014-1354	Outside Work Area Personal Decon C-3	7:11	15:11	3.016	3.016	<17.56
021014-1355	Outside Work Area Waste Decon Upwind C-3	7:13	15:13	3.016	3.016	<17.56
021014-1356	Outside Work Area 2ft from Security Box Downwind B-1	7:14	15:15	3.016	3.016	<17.56
021014-1357	Outside Work Area 4ft from Security Box Downwind B-1	7:16	15:17	3.016	3.016	<17.56
021014-1358	Outside Work Area Center of North Side of Excavation Downwind C-2	7:18	15:19	3.016	3.016	<17.56
021014-1359	Outside Work Area Center of Yard Downwind B-2	7:20	15:21	3.016	3.016	<17.56
021014-1360	Outside Work Area Left of Yard Upwind B-3	7:21	15:22	3.016	3.016	<17.56
021014-1361	Outside Work Area 20ft from the Decon Upwind C-3	7:23	15:23	3.016	3.016	<17.56
021014-1362	Outside Work Area North/West Area Upwind D-3	7:24	15:25	3.016	3.016	<17.56
021014-1363	Outside Work Area 15ft from North/West Gate Area Upwind D-3	7:26	15:26	3.016	3.016	<17.56

FIELD NOTES:

*STRUCTURES /PER MM^2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE

CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE

AIRTEK ENVIRONMENTAL CORP.
39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-
3721
AIRTEKENV.COM

Date: 2/7/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/31/2013
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Creddille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:09 TIME OFF: 15:31
TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURES/PER MM^2*
020714-1332	Inside Work Area Rear of the Electrical Box Downwind B-1	7:09	15:09	3.016	3.016	<17.56
020714-1333	Outside Work Area Personal Decon C-3	7:10	15:10	3.016	3.016	<17.56
020714-1334	Outside Work Area Waste Decon Upwind C-3	7:12	15:13	3.016	3.016	<17.56
020714-1335	Outside Work Area 2ft from Security Box Downwind B-1	7:14	15:14	3.016	3.016	<17.56
020714-1336	Outside Work Area 4ft from Security Box Downwind B-1	7:15	15:15	3.016	3.016	<17.56
020714-1337	Outside Work Area Center of North Side of Excavation Downwind C-2	7:17	15:17	3.016	3.016	<17.56
020714-1338	Outside Work Area Center of Yard Downwind B-2	7:19	15:19	3.016	3.016	<17.56
020714-1339	Outside Work Area Left of Yard Upwind B-3	7:22	15:23	3.016	3.016	<17.56
020714-1340	Outside Work Area 20ft from the Decon Upwind C-3	7:25	15:25	3.016	3.016	<17.56
020714-1341	Outside Work Area North/West Area Upwind D-3	7:28	15:28	3.016	3.016	<17.56
020714-1342	Outside Work Area 15ft from North/West Gate Area Upwind D-3	7:31	15:31	3.016	3.016	<17.56

FIELD NOTES:

*STRUCTURES /PER MM^2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE

CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE

AIRTEK ENVIRONMENTAL CORP.
39-37 29th Street, Long Island City 11101
Phone (718) 937-3720 Fax (718) 937-3721
AIRTEKENV.COM

Date: 2/6/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/31/2013
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Creddille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:13 TIME OFF: 15:32
TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURES/PER MM^2*
020614-1311	Inside Work Area Rear of the Electrical Box Downwind B-1	7:13	15:13	3.016	3.016	<17.56
020614-1312	Outside Work Area Personal Decon C-3	7:16	15:16	3.016	3.016	<17.56
020614-1313	Outside Work Area Waste Decon Upwind C-3	7:18	15:18	3.016	3.016	<17.56
020614-1314	Outside Work Area 2ft from Security Box Downwind B-1	7:20	15:20	3.016	3.016	<17.56
020614-1315	Outside Work Area 4ft from Security Box Downwind B-1	7:21	15:22	3.016	3.016	<17.56
020614-1316	Outside Work Area Center of North Side of Excavation Downwind C-2	7:23	15:24	3.016	3.016	<17.56
020614-1317	Outside Work Area Center of Yard Downwind B-2	7:24	15:25	3.016	3.016	<17.56
020614-1318	Outside Work Area Left of Yard Upwind B-3	7:27	15:27	3.016	3.016	<17.56
020614-1319	Outside Work Area 20ft from the Decon Upwind C-3	7:29	15:29	3.016	3.016	<17.56
020614-1320	Outside Work Area North/West Area Upwind D-3	7:30	15:30	3.016	3.016	<17.56
020614-1321	Outside Work Area 15ft from North/West Gate Area Upwind D-3	7:32	15:32	3.016	3.016	<17.56

FIELD NOTES:

*STRUCTURES /PER MM^2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE

CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE

AIRTEK ENVIRONMENTAL CORP.
39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-
3721
AIRTEKENV.COM

Date: 2/5/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/31/2013
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Creddille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:09 TIME OFF: 15:29
TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURES/PER MM^2*
020514-1290	Inside Work Area Rear of the Electrical Box Downwind B-1	7:09	15:09	3.016	3.016	<17.56
020514-1291	Outside Work Area Personal Decon C-3	7:10	15:10	3.016	3.016	<17.56
020514-1292	Outside Work Area Waste Decon Upwind C-3	7:12	15:12	3.016	3.016	<17.56
020514-1293	Outside Work Area 2ft from Security Box Downwind B-1	7:14	15:14	3.016	3.016	<17.56
020514-1294	Outside Work Area 4ft from Security Box Downwind B-1	7:15	15:15	3.016	3.016	<17.56
020514-1295	Outside Work Area Center of North Side of Excavation Downwind C-2	7:17	15:17	3.016	3.016	<17.56
020514-1296	Outside Work Area Center of Yard Downwind B-2	7:19	15:20	3.016	3.016	<17.56
020514-1297	Outside Work Area Left of Yard Upwind B-3	7:22	15:23	3.016	3.016	<17.56
020514-1298	Outside Work Area 20ft from the Decon Upwind C-3	7:25	15:26	3.016	3.016	<17.56
020514-1299	Outside Work Area North/West Area Upwind D-3	7:26	15:27	3.016	3.016	<17.56
020514-1300	Outside Work Area 15ft from North/West Gate Area Upwind D-3	7:28	15:29	3.016	3.016	<17.56

FIELD NOTES:

*STRUCTURES /PER MM^2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE

CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE

AIRTEK ENVIRONMENTAL CORP.
39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-
3721
AIRTEKENV.COM

Date: 2/4/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/31/2013
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Creddille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:11 TIME OFF: 15:33
TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURES/PER MM^2*
020414-1269	Inside Work Area Rear of the Electrical Box Downwind B-1	7:11	15:12	3.016	3.016	<17.56
020414-1270	Outside Work Area Personal Decon C-3	7:13	15:14	3.016	3.016	<17.56
020414-1271	Outside Work Area Waste Decon Upwind C-3	7:16	15:17	3.016	3.016	<17.56
020414-1272	Outside Work Area 2ft from Security Box Downwind B-1	7:18	15:19	3.016	3.016	<17.56
020414-1273	Outside Work Area 4ft from Security Box Downwind B-1	7:20	15:21	3.016	3.016	<17.56
020414-1274	Outside Work Area Center of North Side of Excavation Downwind C-2	7:21	15:22	3.016	3.016	<17.56
020414-1275	Outside Work Area Center of Yard Downwind B-2	7:23	15:23	3.016	3.016	<17.56
020414-1276	Outside Work Area Left of Yard Upwind B-3	7:24	15:24	3.016	3.016	<17.56
020414-1277	Outside Work Area 20ft from the Decon Upwind C-3	7:27	15:27	3.016	3.016	<17.56
020414-1278	Outside Work Area North/West Area Upwind D-3	7:29	15:29	3.016	3.016	<17.56
020414-1279	Outside Work Area 15ft from North/West Gate Area Upwind D-3	7:33	15:33	3.016	3.016	<17.56

FIELD NOTES:

*STRUCTURES /PER MM^2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE

CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE

AIRTEK ENVIRONMENTAL CORP.
39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-
3721
AIRTEKENV.COM

Date: 2/3/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/31/2013
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Creddille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:10 TIME OFF: 14:33
TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLO W	STRUCTURE S/PER MM^2*
020314-1248	Inside Work Area Rear of the Electrical Box Downwind B-1	7:10	14:11	3.016	3.016	<14.63
020314-1249	Outside Work Area Personal Decon C-3	7:12	14:12	3.016	3.016	<14.63
020314-1250	Outside Work Area Waste Decon Upwind C-3	7:15	14:15	3.016	3.016	<14.63
020314-1251	Outside Work Area 2ft from Security Box Downwind B-1	7:17	14:17	3.016	3.016	<14.63
020314-1252	Outside Work Area 4ft from Security Box Downwind B-1	7:19	14:20	3.016	3.016	<14.63
020314-1253	Outside Work Area Center of North Side of Excavation Downwind C-2	7:22	14:23	3.016	3.016	<14.63
020314-1254	Outside Work Area Center of Yard Downwind B-2	7:26	14:27	3.016	3.016	<14.63
020314-1255	Outside Work Area Left of Yard Upwind B-3	7:28	14:29	3.016	3.016	<14.63
020314-1256	Outside Work Area 20ft from the Decon Upwind C-3	7:30	14:31	3.016	3.016	<14.63
020314-1257	Outside Work Area North/West Area Upwind D-3	7:31	14:32	3.016	3.016	<14.63
020314-1258	Outside Work Area 15ft from North/West Area Upwind D-3	7:32	14:33	3.016	3.016	<14.63

FIELD NOTES:

*STRUCTURES /PER MM^2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE

CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE