

DG Interconnection Procedures Collaborative

February 27, 2017

Interconnection Procedures Collaborative

- State Ombudsman kick-off October 2016
- Goal: develop improvements to Con Edison's internal process for managing interconnections.
- In accordance with the New York State Public Service Commission Standard Interconnection Requirements (SIR)
- CE agrees to implement changes as appropriate following the discussions.
- Informational report filing 6 months from the initial meeting
 - Topics discussed, recommendations developed, and actions taken.

March 1: Solar Installer Training

Registration

AGENDA

- 8:30 - 9:00** - Security Check-in and Con Edison Complimentary Continental Breakfast
- 9:00 - 9:10** **Sustainable CUNY** - Welcome & NYC Solar Partnership Update
- 9:10 – 9:40** **Sustainable CUNY & Meister Consultants Group**
Introduction to Smart DG Hub and Overview of Smart DG Hub Roadmap
- 9:40 - 10:45** **Con Edison**
Interconnection Application Processes for solar and energy storage
- 10:55 - 12:20** **NYC Department of Buildings**
Construction & Electrical Permit Application Processes for solar and energy storage
- 12:20 - 1:15** **Lunch** - Can be purchased in Con Edison cafeteria or nearby restaurants
- 1:15 – 2:30** **Fire Department of New York**
NYC Fire Code Rooftop Access Requirements and Variance Request Process
Energy Storage Fire Code Requirements and Application Process
- 2:40 – 3:40** **DNV GL**
Review of NYC battery testing results and next steps
- 3:50 – 4:45** **Smart DG Hub Roundtable: Storage Outlook and Roadmap**
Panel includes NY-BEST, Meister Consultants Group, Sustainable CUNY, & DNV GL

Con Edison - The Learning Center Auditorium

4382 Vernon Blvd

Long Island City, NY 11101

Agenda

- Future topics and Con Edison work plan
- Topics for today's meeting
 - Regular business meetings
 - SIR workflow
 - Standardizing communications to present consistent options
- Discussion
 - Feedback on templates

Future Topics and Timeline

Suggested dates going forward

March 13 (pm) 2017: webinar

- Guide content drafts for DG technology
 - Company moving forward with PV and fuel cell guides as was presented

March 27 (pm) 2017: in-person

- New service vs DG cases coordination

April 7

- Con Edison provides draft informational report to Collaborative members

April 14 2017: in-person

- Review outstanding items
- Review draft informational report on Collaborative

Filing of Informational Report on Collaborative due April 24.

Process for regular business meetings


- Any DG >5MW normally have regular meetings
- DG Ombudsman Office and Energy Services available for meetings on request
- Pre-application discussions can help set realistic expectations on unusual schedule constraints
- Special billing considerations (RNM, CDG, Offset Tariff, etc) will meetings scheduled near commissioning for rates
- Developer feedback?
 - How to find balance between transparent communications and efficient management of ~125 cases under the new SIR >50kw.

SIR workflow discussion


- Refer to flow chart

March 2016 NYS SIR - Simplified Process Flow Chart for 50kw – 5MW

Pre-Application Report Request



Direct Application



Preliminary Screening Analysis

If any screens fail, applicant must request supplemental screen or CESIR to progress or withdraw application.

- Screens performed
 - Screen A: Is the PCC on a Networked Secondary System?
 - Screen B: Is Certified Equipment Used?
 - Screen C: Is the Electric Power System (EPS) Rating Exceeded?
 - Screen D: Line Configuration Compatible w/ Interconnection Type?
 - Screen E: Simplified Penetration Test
 - Screen F: Simplified Voltage Fluctuation Test
- Deliverable:
 - Pass: Design Approval Letter and Executed Contract
 - Fail: Preliminary Review Letter Template (w/ Options)

Preliminary Screening Results

- Refer to documents

Supplemental Screening Analysis

If any screens fail, applicant must request CESIR to progress or withdraw application.

- **Screen G: Supplemental Penetration Test**

- Where 12 months of line section minimum load data is available, can be calculated, can be estimated from existing data, or determined from a power flow model, is the aggregate Generating Facility capacity on the Line Section less than 100% of the minimum load for all line sections bounded by automatic sectionalizing devices upstream of the Generating Facility?

- **Screen H: Power Quality and Voltage Tests**

- In aggregate with existing generation on the Line Section,
 - a. Can it be determined within the Supplemental Review that the voltage regulation on the line section can be maintained in compliance with current voltage regulation requirements under all system conditions?
 - b. Can it be determined within the Supplemental Review that the voltage fluctuation is within acceptable limits as defined by IEEE 1453 or utility practice similar to IEEE1453?
 - c. Can it be determined within the Supplemental Review that the harmonic levels meet IEEE519 limits at the Point of Common Coupling (PCC)?

- **Screen I: Safety and Reliability Tests**

- Does the location of the proposed Generating Facility or the aggregate generation capacity on the Line Section create specific impacts to safety or reliability that cannot be adequately addressed without a detailed study?

- **Deliverables:**

- Pass: Screen Results and Design Approval Letter and Executed Contract
- Fail: Screen Results and Supplemental Review Letter Template (w/ Options)

Supplemental Screening Analysis Results

- Refer to documents

CESIR Results


- Refer to document: template for engineering review results and next steps

Thank you

February 27, 2017


Appendix Slides

Flow Chart: Regular Application Process for Systems above 50 kW to 5 MW




Flow Chart: Regular Application Process for Systems above 50 kW to 5 MW


System Upgrade and Construction Approval



Flow Chart: Regular Application Process for Systems above 50 kW to 5 MW




Flow Chart: Regular Application Process for Systems above 50 kW to 5 MW



Flow Chart: Regular Application Process for Systems above 50 kW to 5 MW

Final Acceptance and Utility Cost Reconciliation



Flow Chart: Regular Application Process for Systems above 50 kW to 5 MW

